

WHAT TO EXPECT WHEN BEING INSPECTED

- Inspector will make all introductions
- Begin with required paperwork (Required paperwork to be kept on-site)
 - Fire Drill Records
 - Fire Alarm Inspection Records
 - Fire Suppression Records if applicable
 - Hood Suppression Records if applicable
 - Fire Door Inspection Records if applicable
 - Emergency Lighting
 - Monthly 30 second tests
 - Annual 90-minute tests
 - Emergency Plan
 - Staff Training
 - Generator if installed (Permanent)
 - Fire Watch Policies
- Facility Walk
 - Checking all Fire Doors
 - Verifying compliance with all fire rated walls
 - Egress paths
 - Both inside and outside
 - Fire Extinguishers
 - Exit sign illumination
 - Emergency Lighting
 - Inside and outside paths to public way
 - Door Locking if applicable
 - Hazardous Areas
 - Furnace Rooms
 - Storage Rooms
 - Laundry Rooms (Dryer Vents)
 - Address Numbers on Facility
 - Must be seen from road
- Closing Conference
 - Inspector will meet with Administrator, Manager or Staff to report findings
- BFS Region Map

<https://www.arcgis.com/apps/webappviewer/index.html?id=6d3a26b4c12540e1ab4a44b12fcd563&extent=-9930645.4451%2C5059540.6733%2C-8756572.6907%2C5627620.6675%2C102100>